



Please give this sketch to whom ever undertakes the work.

STW Reference

8400198

Address

Trough 1
Coveridge Fields
Wheathill
Bridgnorth
WV16 6QT

Customer to install 1 x 25mm MDPE pipe up to boundary and ensure it complies to Water Supply (Water Fittings) Regulations 1999-

STW Works

1 x new connection of 25mm MDPE service to 7 inch SI main in Private

Traffic Management

The following TM is required:
Barriers will be sufficient.

Boundary: 360780:281104
Main: 360780:281104

Extra Information:

Please ensure that you have a 4" Duct from the point of entry to ground level with minimum 19mm thick insulation. Pipe must be minimum 750mm deep.

Connection will be 21 days from passed inspection subject to highways approval. Unless a road closure is required in which case the delay can be up to 13 weeks from passing.

**SEVERN
TRENT**